

Fence Standards

This design guideline is written to the designer of record (DOR). This guideline is written to document UA standards of work, assist the designers in ensuring UA standards are incorporated into the contract documents and provide a resource to facilitate the design process. It is the designer of record's responsibility to coordinate the criteria set forth in design guideline and in conjunction with the manufacturer requirements and use the most stringent standard.

A. General

1. Standard decorative fence shall be used throughout the campus.
2. While there will be latitude in design variations, the following material specification along with the attached drawings shall be used as the basis for fence design.

B. Limestone

1. Manufactured by Russellville Cut Stone Co., Russellville, Alabama.

C. Brick

1. Shall match, as closely as possible, to the brick of the building to which the fence is adjacent.

D. Metal Fencing

1. Materials shall be cast iron grade, factory primed and field painted, black color.
2. Please refer to Section IV: Standard Drawings, #25 Decorative Fencing.

E. Drawings

1. See Design Guidelines Section IV for Decorative Fencing Drawing.

- End -