


EZ PATH FIRE-RATED PATHWAY—
FOUR GANG KIT WALL PENETRATION
ABOVE CABLE TRAY (TO CORRIDOR)

RESERVE SPACE ABOVE
DOOR FOR HVAC UNIT

GENERAL NOTES:

1. MINIMUM INTERIOR CLEARANCE SPACE: 9'X10' **
2. MINIMUM DATA CLOSET ROOM SPACE: 12'X10'
3. FRONT OF PATCH PANELS AND SWITCHES SHOULD FACE TOWARD THE DOOR.
4. AVOID PLACEMENT OF SERVICE ENTRANCE CONDUITS IN AREA IN FRONT OF EQUIPMENT RACKS.

PLAN VIEW



THE UNIVERSITY OF
ALABAMA

FACILITIES
CONSTRUCTION ADMINISTRATION
DEPARTMENT
1205 14th Street
Tuscaloosa, AL 35401
PHONE: (205) 348-5950
FAX: (205) 348-1588

Sheet Title:

**DATA ROOM - EQUIPMENT
RACK CLEARANCE**

issue date:

DEC.17, 2014

Project:

**CONSTRUCTION ADMINISTRATION
DESIGN GUIDELINES**

CSI division:

32 16 23

1 of 2